

# Tests on electric cables under fire conditions —

## Part 3: Tests on bunched wires or cables —

(Implementation of CENELEC  
HD 405.3 S1)

UDC 621.315.21.3:620.1:614.84

## Committees responsible for this British Standard

The preparation of this British Standard was entrusted by the Cables and Insulation Standards Policy Committee (CIL/-) to Technical Committee CIL/20, upon which the following bodies were represented:

Association of Consulting Engineers  
 Association of Manufacturers of Domestic Electrical Appliances  
 BEAMA Electrical Cable and Cable Accessory Manufacturers' Association  
 British Approvals Service for Cables  
 British Cable Makers Confederation (BCMC)  
 British Plastics Federation  
 British Steel Industry  
 Department of Trade and Industry (Consumer Safety Unit, CA Division)  
 Electricity Association  
 Engineering Equipment and Materials Users' Association  
 Institution of Electrical Engineers  
 London Regional Transport

The following bodies were also represented in the drafting of the standard, through subcommittees and panels:

British Railways Board  
 British Rubber Manufacturers' Association Ltd.  
 British Telecommunications plc  
 ERA Technology Ltd.  
 GAMBICA (BEAMA Ltd.)  
 Institution of Incorporated Executive Engineers  
 London Underground Ltd.  
 Ministry of Defence  
 Queen Mary and Westfield College  
 Telecommunication Cables Group of BCMC  
 Warrington Fire Research Centre

This British Standard, having been prepared under the direction of the Cables and Insulation Standards Policy Committee, was published under the authority of the Standards Board and comes into effect on 15 April 1994

© BSI 02-1999

First published June 1986  
 Second edition April 1994

The following BSI references relate to the work on this standard:  
 Committee reference CIL/20  
 Draft for comment 90/20108 DC

ISBN 0 580 22998 X

### Amendments issued since publication

Amd. No.	Date	Comments

---

# Contents

	Page
Committees responsible	Inside front cover
National foreword	ii
<hr/>	
Foreword	2
Text of HD 405.3 S1	3
<hr/>	
National annex NA (informative) Cross-references	Inside back cover
National annex NB (informative) Guidance on test sample mounting	Inside back cover
<hr/>	

## National foreword

This Part of BS 4066 has been prepared under the direction of the Cables and Insulation Standards Policy Committee. It implements HD 405.3 S1:1993 which was published by the European Committee for Electrotechnical Standardization (CENELEC). It is identical with IEC 332-3:1992 *Tests on electric cables under fire conditions — Part 3: Tests on bunched wires or cables*, published by the International Electrotechnical Commission (IEC). This Part of BS 4066 supersedes BS 4066-3:1986, which is withdrawn.

It should be noted that IEC 332-3:1992 is a Technical Report of type 2. It is not to be regarded as an international standard. A review of IEC 332-3:1992 will be carried out not later than 3 years after its publication with the options of extension for another 3 years, conversion into an international standard, or withdrawal.

Additional guidance is given in National annex NB on test sample mounting.

Part 1 of BS 4066 specifies a method of test on a single vertical insulated wire or cable and the requirement for compliance.

Part 2 of BS 4066 specifies a method of testing a small insulating wire under fire conditions when the method specified in BS 4066-1 is not suitable because some small conductors may melt during application of the flame. Part 2 of BS 4066 also includes the requirement for compliance.

The foreword of HD 405.3 makes reference to the “date of withdrawal” (dow) of the relevant national standard. In this case, the relevant national standard is BS 4066-3:1986. Certificates and marks already awarded may continue to apply to production until 1 March 1999.

A British Standard does not purport to include all the necessary provisions of a contract. Users of British Standards are responsible for their correct application.

**Compliance with a British Standard does not of itself confer immunity from legal obligations.**

### Summary of pages

This document comprises a front cover, an inside front cover, pages i and ii, the EN title page, pages 2 to 22, an inside back cover and a back cover.

This standard has been updated (see copyright date) and may have had amendments incorporated. This will be indicated in the amendment table on the inside front cover.

---

UDC 621.315.21.3:620.1:614.84

Descriptors: Electrical installation, electric cable, fire behaviour test, flame propagation

English Version

## Tests on electric cables under fire conditions Part 3: Tests on bunched wires or cables

(IEC 332-3:1992)

Essais des câbles électriques soumis au feu  
Partie 3: Essais sur des fils ou câbles en nappes  
(CEI 332-3:1992)

Prüfungen an Kabeln und isolierten Leitungen  
unter Brandeinwirkungen  
Teil 3: Prüfungen an gebündelten  
Aderleitungen oder Kabeln  
(IEC 335-3:1992)

This Harmonization Document was approved by CENELEC on 1993-07-06. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for implementation of this Harmonization Document on a national level.

Up-to-date lists and bibliographical references concerning such national implementation may be obtained on application to the Central Secretariat or to any CENELEC member.

This Harmonization Document exists in three official versions (English, French, German).

CENELEC members are the national electrotechnical committees of Austria, Belgium, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.

## CENELEC

European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**Central Secretariat: rue de Stassart 35, B-1050 Brussels**

## Foreword

At the request of the CENELEC Technical Committee TC 20, Electric cables, the International Standard IEC 332-3:1992 was submitted to the CENELEC Unique Acceptance Procedure (UAP) in September 1992 for acceptance as a Harmonization Document.

The text of the International Standard was approved by CENELEC as HD 405.3 S1 on 6 July 1993.

The following dates were fixed:

- latest date of announcement of the HD at national level (doa) 1993-09-01
- latest date of publication of a harmonized national standard (dop) 1994-03-01
- latest date of withdrawal of conflicting national standards (dow) 1994-03-01

For products which have complied with the relevant national standard before 1994-03-01, as shown by the manufacturer or by a certification body, this previous standard may continue to apply for production until 1999-03-01.

Annexes designated “normative” are part of the body of the standard. Annexes designated “informative” are given only for information. In this standard, Annex A and Annex B are informative and Annex ZA is normative.

## Contents

	Page		Page
Foreword	2	2.10 Guidance for cable selection for type approval test	6
Introduction	3	Section 3. Method of mounting test samples and flame application times, for category A, designations F/R and F	
Section 1. General		3.1 Selection of test pieces	6
1.1 Scope	3	3.2 Method of attachment	6
1.2 Normative references	3	3.3 Positioning of test samples	7
Section 2. General details of test procedures		3.4 Flame application time	7
2.1 Test sample and categories	3	Section 4. Method of mounting test samples and flame application times, for category B, designation F	
2.2 Details of the test rig	4	4.1 Selection of test pieces	7
2.3 Determination of number of test pieces	4	4.2 Method of attachment	7
2.4 Mounting of the test sample	4	4.3 Positioning of test samples	7
2.5 Ignition source	5	4.4 Flame application time	8
2.6 Positioning of ignition source	5	Section 5. Method of mounting test samples and flame application times, for category C, designation F	
2.7 Test procedure	5	5.1 Selection of test pieces	8
2.8 Performance requirements and retest procedure	5	5.2 Method of attachment	8
2.9 Measurement of oxygen index (OI)	6	5.3 Positioning of test samples	8
		5.4 Flame application time	8
		Annex A (informative) Details of proposed burner	18
		Annex B (informative) Method of measurement of oxygen index for non-metallic components in electric cables	18
		Annex ZA (normative) Other international publications quoted in this standard with the references of the relevant European publications	22
		Figure 1 — Fire test rig	11
		Figure 1a — Thermal insulation of back and sides of the test chamber	12
		Figure 2 — Standard tubular ladder for cable test	13
		Figure 2a — Wide tubular ladder for cable test	13
		Figure 3 — Arrangement of test sample on ladder	14
		Figure 4 — Burner	15
		Figure 4a — Burners	15
		Figure 5 — Typical example of gas flow controls	17
		Figure B.1	21
		Table 1 — Summary of test conditions	9
		Table 2 — Summary of guidance data for the selection of cables for type approval tests	10

## Introduction

Parts 1 and 2 of IEC 332 specify methods of test for flame propagation characteristics for a single vertical insulated wire or cable. It cannot be assumed that, because a cable or wire meets the requirements of parts 1 and 2, a bunch of similar cables or wires will behave in a similar manner. This is because the propagation of flame along a bunch of cables depends on a number of features, such as:

- a) the volume of combustible material exposed to the fire and to any flame which may be produced by the combustion of the cables;
- b) the geometrical configuration of the cables and their relationship to an enclosure;
- c) the temperature at which it is possible to ignite the gases emitted from the cables;
- d) the quantity of combustible gas released from the cables for a given temperature rise;
- e) the volume of air passing through the cable installation;
- f) the construction of the cable, e.g. armoured or unarmoured.

All of the foregoing assume that the cables are able to be ignited when involved in an external fire.

This report gives details of a test where a number of cables are bunched together to form various test sample installations. Three sections, 3 to 5, provide details of different test categories having varying volumes of non-metallic material per metre of the test sample subjected to the test.

The method of mounting described as category A, designation F/R in section 3 is intended for special cable designs used in particular installations e.g. power stations.

The method of mounting described as category A, designation F in section 3 is introduced so that a consistent comparison with sections 4 and 5 can be made on the effect of increased volume of non-metallic material and test duration.

## Section 1. General

### 1.1 Scope

This Technical Report describes a method of type approval testing to define the ability of bunched cables to restrain flame propagation in defined conditions regardless of their application, i.e. power, telecommunications (including data transmission and optical fibre cables), etc.

Three categories are defined and distinguished by test duration, and the volume of non-metallic material of the sample under test (see Table 1); they are not necessarily related to different safety levels in actual cable installations. Category A has two designations for the method of mounting.

## 1.2 Normative references

The following normative documents contain provisions which, through reference in this text, constitute provisions of this Technical Report. At the time of publication, the editions indicated were valid. All normative documents are subject to revision, and parties to agreements based on this Technical Report are encouraged to investigate the possibility of applying the most recent editions of the normative documents indicated below. Members of IEC and ISO maintain registers of currently valid International Standards.

IEC 332-1:1979, *Tests on electric cables under fire conditions — Part 1: Test on a single vertical insulated wire or cable.*

IEC 332-2:1989, *Tests on electric cables under fire conditions — Part 2: Test on a single small vertical insulated copper wire or cable.*

IEC 811-1-3:1985, *Common test methods for insulating and sheathing materials of electric cables — Part 1: Methods for general application — Section 3: Methods for determining the density — Water absorption tests — Shrinkage test.*

## Section 2. General details of test procedures

### 2.1 Test sample and categories

The test sample should comprise a number of test pieces of cable from the same length, each having a minimum length of 3,5 m.

The total number of 3,5 m test pieces in the test sample should be in accordance with one of the three categories as follow:

#### Category A

The number of test pieces required to provide a nominal total volume of non-metallic material of 7 litres per metre.

#### Category B

The number of test pieces required to provide a nominal total volume of non-metallic material of 3,5 litres per metre.

#### Category C

The number of test pieces required to provide a nominal total volume of non-metallic material of 1,5 litres per metre.

## 2.2 Details of the test rig

### 2.2.1 Enclosure and air supply

The test rig (Figure 1) should comprise a vertical test chamber having a width of 1 000 mm ± 100 mm, a depth of 2 000 mm ± 100 mm and a height of 4 000 mm ± 100 mm; the floor of the chamber should be raised above ground level. The test chamber should be nominally airtight along its sides, air being admitted at the base of the test chamber through an aperture of 800 mm ± 20 mm × 400 mm ± 10 mm situated 150 mm ± 10 mm from the front wall of the test chamber.

The air flow should be adjusted to a rate of 5 000 l/min ± 500 l/min at a constant controlled temperature of (20 ± 10) °C and measured at the outlet or inlet side before the test commences. These parameters should be preferably regulated during the test.

An outlet 300 mm ± 30 mm × 1 000 mm ± 100 mm should be made at the rear edge of the top of the test chamber. The back and sides of the test chamber should be thermally insulated to give a coefficient of heat transfer of approximately 0,7 W/(m<sup>2</sup>·K). For example, a steel plate 1,5 mm to 2,0 mm thick covered with 65 mm of mineral wool with a suitable external cladding is satisfactory (see Figure 1a). The distance between the ladder and the rear wall of the chamber is 150 mm ± 10 mm, and between the bottom rung of the ladder and the ground 400 mm ± 5 mm. The clearance between the lowest point of the test piece and the ground is approximately 100 mm (see Figure 3).

### 2.2.2 Ladder types

There are two types of ladder; a standard ladder of 500 mm width and a wide ladder of 800 mm width. Details of the types of ladder and the methods of mounting to be used are provided in sections 3 to 5 of this report (see Figure 2, Figure 2a, Figure 3, Figure 3a, Figure 3b, Figure 3c and Figure 3d).

### 2.2.3 Smoke cleaning attachment

Legal requirements may make it necessary for equipment for collecting and washing the smoke to be fitted to the test chamber. This equipment should be such as to collect the smoke leaving the chamber without causing a change in the air flow rate through the test chamber.

## 2.3 Determination of number of test pieces

In order to calculate the appropriate number of test pieces, it is necessary to determine the volume per metre of non-metallic material of one test piece.

A section of cable which should not be less than 0,3 m is carefully cut to ensure that the surfaces are at right angles to the cable axis, thus enabling precise measurements of its length.

Each non-metallic material  $C_i$  should be extracted from the test piece and weighed. Any less than 5 % of the total non-metallic weight should be discarded.

Where semi-conducting screens cannot be removed from the insulating material, the components may be considered as one for the purpose of measuring their weight and specific gravity.

The specific gravity of each non-metallic component (including cellular material) should be measured in an appropriate way, e.g. clause 8 of IEC 811-1-3, in order to obtain values expressed to the second decimal place. Tapes and fibrous components should be assumed to have an effective specific gravity of 1.

The volume  $V_i$  (litres per metre of cable) of each non-metallic material  $C_i$  is calculated as follows:

$$V_i = \frac{M_i}{\rho_i \times l}$$

where

$M_i$  is the mass of the component  $C_i$  (kg)

$\rho_i$  is the specific gravity of the component  $C_i$  (kg/dm<sup>3</sup>)

$l$  is the length of the section of cable (m)

The total volume,  $V$ , of the non-metallic materials contained in one metre of cable is equal to the sum of the individual volumes  $V_1$ ,  $V_2$ , etc.

The closest integer (0,5 and above corresponding to 1) of the number of test pieces to be mounted is obtained by dividing the volume per metre of the test category specified in clause 2.1 of this section by the total volume,  $V$ , of non-metallic material per metre of cable.

## 2.4 Mounting of the test sample

The methods of mounting the pre-determined number of test pieces to form the test sample are fully described in sections 3, 4 and 5.

Two methods of mounting (designations F/R and F) are applicable to category A. Only designation F applies to categories B and C.

For identification purposes the following abbreviated notations may be used:

Category A, designation F/R — 332-3A F/R

Category A, designation F — 332-3A F

Category B, designation F — 332-3B F

Category C, designation F — 332-3C F



## 2.5 Ignition source

The ignition source should be one or two ribbon-type propane gas burners and their own set of flow meters, complete with venturi mixer, and whose flame-producing surface consists of a flat metal plate 341 mm long and 30 mm wide through which 242 holes of 1,32 mm in diameter are drilled on 3,2 mm centres in three staggered rows of 81, 80 and 81 holes each to form an array having the nominal dimensions 257 mm × 4,5 mm as shown in Figure 4. As the burner plate may be drilled without the use of a drilling jig, the spacing of the holes may vary slightly. Additionally, a row of small holes may be milled on each side of the burner plate to serve as pilot holes with the function of keeping the flame burning.

**NOTE** To ensure reproducibility between results from different testing stations, it is recommended that the proposed burner, which is readily available, be used. For details, see Annex A.

Each burner should be fitted with an accurate means of controlling the fuel and air input flow rates. Figure 5 shows an example of a control system. The calibration of the propane rotameter should be checked after installation with a flow meter to ensure that the pipework and the venturi have not affected the calibration.

Corrections for the variations in temperature and pressure from that specified on the propane rotameter should be applied when necessary.

For the purpose of this test, the air should have a dew-point not higher than 0 °C and the input should be 76,7 l/min ± 4,7 l/min; the propane flow rate should be 13,3 l/min ± 0,5 l/min at one atmosphere and 20 °C to provide a nominal  $73,7 \pm 1,68 \times 10^6$  J/h ( $70\,000 \pm 1\,600$  Btu/h)<sup>1)</sup> to each burner.

**NOTE** The net heat of combustion is used to calculate the propane flow rate.

## 2.6 Positioning of ignition source

For the test the burner should be arranged horizontally at a distance of 75 mm ± 5 mm from the front surface of the cable sample and 600 mm ± 5 mm above the floor of the test chamber. The point of application of the burner flame should lie in the centre between two cross-bars on the ladder and at least 500 mm ± 5 mm above the lower end of the sample (see Figure 3).

Adjustment of air and gas flows prior to the test may be carried out away from the test position.

Where two burners are used in tandem for the test category A designation F in combination with the wide ladder — see section 3 — they should be positioned as shown in Figure 4a.

<sup>1)</sup> This is also equivalent to 20,5 kW ± 0,5 kW.

## 2.7 Test procedure

### 2.7.1 Test conditions

The test should not be carried out if the external wind speed measured by an anemometer fitted on the top of the test rig is greater than 8 m/s and should not be carried out if the temperature of the inside walls is below 5 °C or above 40 °C measured at a point approximately 1,5 m above floor level, 50 mm from a side wall, and 1,0 m from the door. The enclosure door shall be closed throughout the test.

The cables or test pieces forming the test sample should be conditioned at a temperature of  $(23 \pm 5)$  °C for at least 16 h before commencing the test. The test chamber should be dry.

### 2.7.2 Flame application times

See sections 3, 4 and 5.

## 2.8 Performance requirements and retest procedure

### 2.8.1 Performance requirement

After burning has ceased, the test sample should be wiped clean. If burning has not ceased after a maximum time of 1 h from the completion of the test flame period, the flame should be extinguished.

All soot is to be ignored if, when wiped off, the original surface is undamaged. Softening or any deformation of the non-metallic material is also to be ignored. The maximum extent of the damage is measured to one decimal place from the bottom edge of the burner to the onset of char, which is defined as follows:

Press against the cable surface with a sharp object, e.g. a knife blade. Where the surface changes from a resilient to a brittle (crumbling) surface, this indicates the onset of char.

The maximum extent of the charred portion measured on the test sample should not have reached a height exceeding 2,5 m above the bottom edge of the burner, neither at the front nor the rear of the ladder.

### 2.8.2 Retest procedure

In the case of doubt, two further tests should be undertaken as detailed in clause 2.7. The test should be deemed as satisfactory if both tests meet the requirements of 2.8.1.

## 2.9 Measurement of oxygen index (OI)

If required, the oxygen index of all non-metallic materials should be measured in accordance with the procedure given in Annex B. Components contributing less than 5 % of the non-metallic weight may be ignored.

The values of OI should be recorded and may be used as a basis for quality control of any subsequent production to ensure compliance with the type approval test.

Correlation of the OI values with propagation along the cables under fire conditions is not implied.

## 2.10 Guidance for cable selection for type approval test

The choice of conductor cross-section for type approval tests should be agreed between purchaser and manufacturer but it shall comply with the following restrictions:

The limited capacity of the ladders requires consideration of the conductor cross-section selected for testing to ensure that the volume of non-metallic material can be accommodated within the prescribed method of mounting. Moreover, the testing of a sample consisting of a single test piece shall also be avoided.

Category A, designation F/R

For cables having a conductor cross-section greater than 35 mm<sup>2</sup>, the selection of cable shall not require the placement on each face of the ladder of more cables than the number necessary to form a single layer of 300 mm width on each side, allowing for a space between each cable equal to half the cable diameter but not exceeding 20 mm.

Category A, designation F

For cables having a conductor cross-section greater than 35 mm<sup>2</sup>, the selection of cable shall not require the placement on a single face of the ladder of more cables than the number necessary to form a single layer of 600 mm width, allowing for a space between each cable equal to half the cable diameter but not exceeding 20 mm.

Category B, designation F

For cables having a conductor cross-section greater than 35 mm<sup>2</sup>, the selection of cable shall not require the placement on a single face of the ladder of more cables than the number necessary to form a single layer of 300 mm width, allowing for a space between each cable equal to half the cable diameter but not exceeding 20 mm.

Category C, designation F

The size of cable selected shall require a sample of at least two test pieces to be mounted.

For cables having a conductor cross-section greater, than 35 mm<sup>2</sup>, the selection of cable shall not require the placement on a single face of the ladder of more cables than the number necessary to form a single layer of 300 mm width, allowing for a space between each cable equal to half the cable diameter but not exceeding 20 mm.

Where designation F is used for categories A, B and C, and where the cable size is 35 mm<sup>2</sup> or smaller, there is no restriction on the conductor cross-section selected. This applies also to telecommunication, data transmission and optical cables.

This information is summarized in Table 2.

## Section 3. Method of mounting test samples and flame application times, for category A, designation F/R or F

### 3.1 Selection of test pieces

The number of test pieces should be selected to provide a nominal total non-metallic volume of 7 litres/metre calculated according to clause 2.3. A summary of the test conditions is given in Table 1. For type approval test the cable conductor cross-sections should be chosen in accordance with clause 2.10 and Table 2.

### 3.2 Method of attachment

For cables having a conductor cross-section exceeding 35 mm<sup>2</sup>, each test piece should be attached individually to each rung of the ladder by means of a metal wire (steel or copper) between 0,5 mm and 1,0 mm in diameter.

For cables with a conductor cross-section of 35 mm<sup>2</sup> or less, the same method should be used whenever the test pieces are mounted in a single layer.

If several layers are required to make up a test sample, the test pieces should be attached in discrete bundles of a width equal to five test pieces using the specified metal wire, each separate bundle being attached to that adjacent by the outer test pieces. For consistency it is recommended that discrete bunches touching are secured together at every rung (see Figure 3d).

### 3.3 Positioning of test samples

#### 3.3.1 Cables with a conductor cross-section not exceeding 35 mm<sup>2</sup>

For such cables, only the method of mounting designation F is applicable. The test pieces should be placed touching on the front of the standard ladder in one or more layers so that the width of test sample does not exceed 300 mm. There should be a minimum distance of 50 mm between the edge of the test sample and the inside of the ladder uprights.

#### 3.3.2 Cables with a conductor cross-section exceeding 35 mm<sup>2</sup>

For such cables, two methods of mounting are given (see Table 1).

##### 3.3.2.1 Designation F/R

The test pieces should be attached to the front of the standard ladder in a single layer up to a total width of 300 mm with a space between each test piece of  $0,5 \times$  the cable diameter but not exceeding 20 mm. The remaining test pieces should be mounted on the rear of the ladder starting from the centre (see Figure 3c) with a maximum width of 300 mm. There should be a minimum distance of 50 mm between the edge of the test sample and the inside of the ladder uprights.

##### 3.3.2.2 Designation F

The test pieces should be attached in a single layer to the front of the ladder with a space between each test piece of  $0,5 \times$  the cable diameter but not exceeding 20 mm. The ladder may be either standard or wide depending on whichever is necessary to ensure that the gap between the edges of the test sample and the inside of the ladder uprights is not less than 50 mm, i.e. the maximum width of the test sample for the standard ladder should be 300 mm and for the wide ladder 600 mm (see Figure 3a and Figure 3b).

### 3.4 Flame application time

For both F and F/R designations, and all sizes of conductor cross-section, the test flame should be applied for 40 min.

## Section 4. Method of mounting test samples and flame application times, for category B, designation F

### 4.1 Selection of test pieces

The number of test pieces should be selected to provide a nominal total non-metallic volume of 3,5 litres per metre calculated according to clause 2.3. A summary of the test conditions is given in Table 1. For type approval tests, the cable conductor cross-sections should be chosen in accordance with clause 2.10 and Table 2.

### 4.2 Method of attachment

For cables having a conductor cross-section exceeding 35 mm<sup>2</sup>, each test piece should be attached individually to each rung of the ladder by means of a metal wire (steel or copper) between 0,5 mm and 1,0 mm in diameter.

For cables with a conductor cross-section of 35 mm<sup>2</sup> or smaller, the same method should be used whenever the test pieces are mounted in a single layer.

If several layers are required to make up a test sample, the test pieces should be attached in discrete bundles of a width equal to five test pieces using the specified metal wire, each separate bundle being attached to that adjacent by the outer test pieces. For consistency it is recommended that discrete bunches touching are secured together at every rung (see Figure 3d).

### 4.3 Positioning of test samples

#### 4.3.1 Cables with a conductor cross-section not exceeding 35 mm<sup>2</sup>

The test pieces should be placed touching on the front of the standard ladder in one or more layers so that the width of the test sample does not exceed 300 mm. There should be a minimum distance of 50 mm between the edge of the test sample and the inside of the ladder uprights.

#### 4.3.2 Cables with any conductor cross-section exceeding 35 mm<sup>2</sup>

The test pieces should be attached in a single layer to the front of the standard ladder with a space between each test piece of  $0,5 \times$  cable diameter but not exceeding 20 mm. The maximum width of test sample should be 300 mm (see Figure 3a). There should be a minimum distance of 50 mm between the edge of the test sample and the inside of the ladder uprights.

#### 4.4 Flame application time

For all sizes of conductor cross-section, the test flame should be applied for 40 min.

### Section 5. Method of mounting test samples and flame application times, for category C, designation F

#### 5.1 Selection of test pieces

The number of test pieces should be selected to provide a nominal total non-metallic volume of 1,5 litres per metre calculated according to clause 2.3. A summary of test conditions is given in Table 1. For type approval tests the cable conductor cross-sections should be chosen in accordance with clause 2.10 and Table 2.

#### 5.2 Method of attachment

For cables having a conductor cross-section exceeding  $35 \text{ mm}^2$ , each test piece should be attached individually to each rung of the ladder by means of a metal wire (steel or copper) between 0,5 mm and 1,0 mm in diameter.

For cables with conductor cross-section  $35 \text{ mm}^2$  or smaller, the same method should be used whenever the test pieces are mounted in a single layer.

If several layers are required to make up a test sample, the test pieces should be attached in discrete bundles of a width equal to five test pieces using the specified metal wire, each separate bundle being attached to that adjacent by the outer test pieces. For consistency it is recommended that discrete bundles touching are secured together at every rung (see Figure 3d).

#### 5.3 Positioning of test samples

##### 5.3.1 Cables with a conductor cross-section not exceeding $35 \text{ mm}^2$

The test pieces should be placed touching on the front of the standard ladder in one or more layers so that the width of test sample does not exceed 300 mm. There should be a minimum distance of 50 mm between the edge of the test sample and the inside of the ladder uprights.

##### 5.3.2 Cables with a conductor cross-section exceeding $35 \text{ mm}^2$

The test pieces should be attached in a single layer to the front of the standard ladder with a space between each test piece of  $0,5 \times$  the cable diameter but not exceeding 20 mm. The maximum width of the test sample should be 300 mm (see Figure 3a). There should be a minimum distance of 50 mm between the edge of the test sample and the inside of the ladder uprights.

#### 5.4 Flame application time


For all sizes of conductor cross-section, the test flame should be applied for 20 min.


**Table 1 — Summary of test conditions**

Category and designation	A F/R	A F		B F		C F		
Range of conductor cross-sections (mm <sup>2</sup> )	> 35 <sup>a</sup>	≤ 35 <sup>b</sup>	> 35 <sup>a</sup>		≤ 35 <sup>b</sup>	> 35 <sup>a</sup>	≤ 35 <sup>b</sup>	> 35 <sup>a</sup>
Non-metallic volume per metre of test sample (I)	7	7	7	7	3,5	3,5	1,5	1,5
Number of layers: For the standard ladder: Maximum width of test sample: 300 mm	2 (front and rear of ladder)	≥ 1	1	—	≥ 1	1	≥ 1	1
For the wide ladder: Maximum width of test sample: 600 mm	—	—	—	1	—	—	—	—
Positioning of test pieces	spaced	touching	spaced		touching	spaced	touching	spaced
Flame application time (min)	40	40	40		40		20	
Number of burners	1	1	1	2	1	1	1	1
<sup>a</sup> At least one conductor greater than 35 mm <sup>2</sup> <sup>b</sup> No conductor cross-section exceeding 35 mm <sup>2</sup>								


**Table 2 — Summary of guidance data for the selection of cables for type approval tests**


Size of cable cross-section	Cables with conductors having cross-sections $\leq 35 \text{ mm}^2$ and telecommunication cables			Cables having conductors with at least one cross-section $> 35 \text{ mm}^2$			
	A F	B F	C F	A F/R	A F	B F	C F
Limitation on cable choice to provide the required nominal volume of non-metallic material	<i>At least two test pieces</i>			<i>Maximum two layers (front and rear) 300 mm wide including specified gaps</i>	<i>Maximum one layer 600 mm wide including specified gaps<sup>a</sup></i>	<i>Maximum one layer 300 mm wide including specified gaps</i>  <i>At least two test pieces</i>	<i>Maximum one layer 300 mm wide including specified gaps</i>  <i>At least two test pieces</i>
<p><sup>a</sup> <i>Examples for category A, designation F:</i></p> <p><i>Example 1:</i> Single core cable, <math>1 \times 70 \text{ mm}^2</math> conductor cross-section; outside diameter 17 mm; 0,2 litres per metre of non-metallic material. Maximum width available for test sample = 600 mm. To achieve 7 litres per metre would require 35 test pieces giving a total width of: <math>35 \times 17 \text{ mm} + 34 \times 8,5 \text{ mm} = 884 \text{ mm}</math>. This cable cannot comply with the limitations on choice. Type approval testing arrangements should therefore be made by agreement between the manufacturer and customer or test authority.</p> <p><i>Example 2:</i> Three-core cable: <math>3 \times 50 \text{ mm}^2</math> conductor cross-section; outside diameter 29 mm; 0,55 litres per metre of non-metallic material. Maximum width available for test sample = 600 mm. To achieve 7 litres per metre would require 12,7 test pieces. 13 test pieces give a total width of: <math>13 \times 29 \text{ mm} + 12 \times 14,5 \text{ mm} = 551 \text{ mm}</math>. This cable complies with the limitations on choice.</p>							















242 trous ronds de 1,32 mm de diamètre  
placés en quinconce à 3,2 mm de distance  
sur trois rangées de 81, 80 et 81 trous centrés  
sur l'avant du brûleur  
242 round holes, 1,32 mm in diameter  
on 3,2 mm centres, staggered in three rows  
of 81, 80 and 81 holes, centred on the face  
of the burner




CEI-IEC 25492


*Dimensions en millimètres*  
*Les valeurs sont approximatives*

*Dimensions in millimetres*  
*Values are approximative*

Figure 4 — Burner



Licensed Copy: :FULLNAME, : DATE, Uncontrolled Copy, (c) BSI



Les tuyaux de jonction allant au débitmètre et à la flamme pilote peuvent avoir un diamètre extérieur de 1/4 de pouce ou 8 mm. Les tubulures d'alimentation en air et en propane du brûleur peuvent avoir un diamètre extérieur de 15 mm. Un allumeur électrique et un interrupteur de sécurité pour les bobines des électrovannes peuvent compléter le circuit.

#### CLÉ

- a Entrée du propane
- b Entrée de l'air
- c Pièce en T réductrice
- d Vanne ouvert/fermé
- e Régulateur de pression
- f Filtre
- g Jauge de pression
- h Vanne de contrôle
- r Débitmètres (type rotamètre)
- v Electrovanne
- p Ligne pilote (facultatif)

For lines to the flowmeter and pilot flame, 1/4 inch or 8 mm outer diameter is suitable. For air and propane to the burner 15 mm outer diameter is suitable. Ignition transformer and a safety switch for the solenoid valve will complete the circuitry.

#### KEY

- a Propane input
- b Air input
- c Reducing tee-piece
- d On/off valve
- e Pressure regulator
- f Filter
- g Pressure gauge
- h Control valve
- r Flowmeters (rotameter type)
- v Solenoid valve
- p Pilot line (optional)

Figure 5 — Typical example of gas flow controls

## Annex A (informative)

### Details of proposed burner

A burner (catalogue number 10L11-55) and venturi mixer (catalogue number 14 – 18) complying with the requirements of clause 2.4 can be obtained from:

American Gas Furnace  
P.O. Box 496  
140 Spring Street  
Elizabeth, New Jersey 07207  
USA

TEL: +1 201 352 2120  
TELEFAX: +1 201 352 5174

## Annex B (informative)

### Method of measurement of oxygen index for non-metallic components in electric cables

#### B.1 Scope

This method describes a procedure which examines the relative flammability of non-metallic components taken from or used in electric cables by measuring the minimum concentration of oxygen in a mixture of oxygen and nitrogen that will just support flaming combustion. This method is presently limited to the use of physically self-supporting test specimens.

#### B.2 Definition

##### oxygen index

the minimum concentration of oxygen, expressed as volume per cent, in a mixture of oxygen and nitrogen that will just support combustion of a material under the conditions of this method

#### B.3 Principle of method

The minimum concentration of oxygen in a mixture of oxygen and nitrogen that will just support combustion is measured under equilibrium conditions of "candle-like" burning. The balance between the heat from the combustion of the specimen and the heat lost to the surroundings establishes the equilibrium.

#### B.4 Apparatus

**B.4.1** The test column shall consist of a heat-resistant glass tube of one of the types listed below. The bottom of the column or the base to which the tube is attached shall contain non-combustible material to mix and distribute evenly the gas mixture entering at this base. A wire screen shall be placed above the non-combustible material to catch falling fragments and aid in keeping the base of the column clean.

Means shall be provided for checking or ensuring that the temperature of the gas mixture entering the chimney is  $23\text{ }^{\circ}\text{C} \pm 2\text{ }^{\circ}\text{C}$ . If the means involve an internal probe, its position and profile shall be designed to minimize turbulence within the chimney.

	Minimum inside diameter mm	Height		Restricted upper opening diameter	
		minimum mm	maximum mm	minimum mm	maximum mm
Column A	75	450	—	75	—
Column B	95	210	310	40	50

**B.4.2** A suitable timer capable of indicating at least 10 min and accurate to 1 s.

##### B.4.3 Specimen holder

Any small holding device that will support the specimen at its base and hold it vertically in the centre of the column is acceptable.

##### B.4.4 Gas supplies

The gas mixture required for the test may be prepared using oxygen and/or nitrogen of commercial grades or better (> 98 % purity) and/or clean air as appropriate (air contains 20,9 % oxygen).

The moisture content of the gas mixture entering the test chimney shall be less than 0,1 % by mass.

NOTE It cannot be assumed that supplies of bottled oxygen or nitrogen will always contain less than 0,1 % by mass of water, although moisture contents of 0,003 % to 0,01 % by mass are typical. In particular, if the bottle has been charged under adverse conditions, a supply drawn from the last 10 % of the bottle may contain between 0,1 % and 0,5 % by mass of water as the gas pressure diminishes with respect to water vapour pressure at ambient temperatures. Hence the gas supply system should incorporate a drying device or provision should be made for measuring the moisture content.

#### **B.4.5 Concentration of oxygen measurement**

The concentration of oxygen shall be measured by one of the following methods. In cases of dispute method i) shall be used:

- i) The concentration of oxygen in the mixed gases shall be determined by measuring the paramagnetism of the oxygen.
- ii) Gas measurement and control devices. Measuring and control devices shall be used which will measure and control the composition of the gas mixture in the test chimney so that the concentration of oxygen in the gas mixture is known to an accuracy of  $\pm 0,5$  % by volume of the mixture.

#### **B.4.6 Ignition source**

The igniter should be a butane gas torch with attachments as shown in Figure B.1. The flame length should be approximately 30 mm measured in air from the top of the shield.

NOTE A suitable ignition source is a "Ronson Butane Blowtorch" with a "Stanton Redcroft" attachment (spares reference No. 9234).

#### **B.4.7 Extractor fan**

To ensure the removal of smoke, soot and toxic fumes, the apparatus shall be sited in an area having efficient exhaust facilities that do not interfere with the test results.

### **B.5 Test specimen**

**B.5.1** The test specimens are flat rectangular sheets having the following dimensions:

length	70 mm to 150 mm
width	6,5 mm $\pm$ 0,5 mm
thickness	3,0 mm $\pm$ 0,5 mm

**B.5.2** The specimens may be obtained by moulding, cutting or machining from the cable constituents to be tested. Where this is not possible with a cable containing vulcanized material, a moulded, vulcanized slab prepared from material sampled during manufacture of the same production batch shall be used.

**B.5.3** The edges of the test pieces shall be smooth and free from fuzz or burrs of material from machining or peripheral flash from moulding.

### **B.6 Procedure**

**B.6.1** Each specimen shall be marked with two lines 8 mm and 58 mm from the top. For ease of viewing each line should be marked on at least two adjacent faces. For white or coloured specimens an ordinary ball-point pen may be used. For black specimens a contrasting ink should be used. The ink shall be allowed to dry before the test.

Clamp the specimen in the holder vertically in the approximate centre of the column with the top of the specimen at least 100 mm below the top of the open column.

If a restricted opening column is used as specified in **B.4.1**, the top of the specimen shall be at least 40 mm below the opening.

**B.6.2** The test shall be carried out at  $(23 \pm 2)$  °C and the samples shall be pre-conditioned at  $(23 \pm 2)$  °C and at a relative humidity of  $50 \% \pm 5 \%$  for 24 h.

**B.6.3** Set the desired initial concentration of oxygen flowing through the column. The gas flow rate in the column shall be  $40 \text{ mm/s} \pm 10 \text{ mm/s}$  as calculated at laboratory conditions from the total flow of gas in cubic millimetres per second divided by the area of the column in square millimetres.

**B.6.4** Allow the gas to flow for at least 30 s to purge the system.

**B.6.5** Apply the ignition source so that 6 mm (approximately) of the flame shall impinge on the top of the specimen. As the specimen burns, the ignition source shall be lowered to maintain the flame impingement of approximately 6 mm. The oxygen concentration shall not be adjusted after lighting the test piece.

The ignition flame shall be applied until the specimen has burnt down to the 8 mm line. It shall then be removed and timing commenced.

**B.6.6**

- i) If the specimen burns for 3 min or longer, or for a length of 50 mm or longer, the specimen shall be extinguished and the concentration shall be recorded at or after 3 min or at or after 50 mm.
- ii) If the specimen stops burning before 3 min and for less than 50 mm the concentration of oxygen shall be taken as being low. The extinguishing time shall be recorded.

**B.6.7** Insert a new specimen. (A specimen may be re-used if cooled and the burned end cut off, provided it complies with **B.5.2** and **B.6.2**.)

Adjust the oxygen concentration on the results of **B.6.6**. Repeat the test procedures of **B.6.4** to **B.6.6**.

**B.6.8** Continue the test according to **B.6.7** with one test only at each oxygen concentration until two concentrations are obtained which satisfy the conditions given in items a), b) and c) below:

- a) the first oxygen concentration gives the result that the specimen burns for at least 3 min or along a length of at least 50 mm;
- b) the second oxygen concentration gives the result that the specimen extinguishes itself within less than 3 min and burns along a length of less than 50 mm;
- c) the numerical difference between the percent oxygen concentration found in items a) and b) shall not exceed 0,25.

The oxygen concentration corresponding to item a) above is taken as the approximate oxygen index value at this stage.

**B.6.9** Confirmatory tests shall now be carried out using the following criteria:

At each oxygen concentration tried, the majority result of three determinations shall be recorded as the result for that concentration. (Results from the original series, obtained in **B.6.8** shall be included.)

The first concentration tried should be the approximate oxygen index value obtained in **B.6.8**. Tests shall then be continued in steps not exceeding  $\pm 0,25$  % oxygen concentration either up or down depending on the majority result at this approximate oxygen index value.

When majority results are obtained which satisfy items a), b) and c) of **B.6.8**, testing shall be discontinued.

The majority result corresponding to item a) of **B.6.8** is taken as the absolute oxygen index value of the material under test.

**B.7 Report**

The report shall include the following:

- i) the absolute oxygen index value;
- ii) a description of any unusual behaviour observed, during the test.

**B.8 Confirmation of minimum oxygen index**

The procedure which has been described is for determining the absolute value of the oxygen index. Where it is required to check that the oxygen index is above a minimum specified value, the procedure outlined in **B.6.3**, **B.6.4** and **B.6.5** shall be adopted and the requirement is satisfied if item ii) of **B.6.6** is applicable.

NOTE 1 *Test column*

It has been found that if the glass test column becomes unduly hot, lower oxygen index values may be obtained. It is therefore suggested that two test columns should be available for use.


NOTE 2 *Calibration*

Suitable methods of calibration and degree of accuracy of equipment are to be incorporated in due course.

NOTE 3 *Flowmeters*

If flowmeters are used which are calibrated for air, corrections should be made for the densities of the gases.





**Annex ZA (normative)****Other international publications quoted in this standard with the references of the relevant European publications**

This Harmonization Document incorporates by dated or undated reference, provisions from other publications. These normative references are cited at the appropriate places in the text and the publications are listed hereafter. For dated references, subsequent amendments to or revisions of any of these publications apply to this Harmonization Document only when incorporated in it by amendment or revision. For undated references the latest edition of the publication referred to applies.

NOTE When the international publication has been modified by CENELEC common modifications, indicated by (mod), the relevant EN/HD applies.

IEC publication	Date	Title	EN/HD	Date
332-1	1979	<i>Tests on electric cables under fire conditions</i>	HD 405.1 S1	1983
		<i>Part 1: Test on a single vertical insulated wire or cable</i>	HD 405.1 S1 A1	1992
332-2	1989	<i>Part 2: Test on a single small vertical insulated copper wire or cable</i>	HD 405.2 S1	1991
811-1-3	1985	<i>Common test methods for insulating and sheathing materials of electric cables</i>	HD 505.1.3 S2 <sup>a</sup>	1988
		<i>Part 1: Methods for general application Section 3 — Methods for determining the density — Water absorption tests — Shrinkage test</i>		

<sup>a</sup> HD 505.1.3 S2 includes A1:1990 to IEC 811-1-3

## National annex NA (informative)

### Cross-references

Publication referred to	Corresponding British Standard
	BS 4066 <i>Tests on electric cables under fire conditions</i>
IEC 332-1:1979	Part 1:1980 <i>Method of test on a single vertical insulated wire or cable</i>
IEC 332-2:1989	Part 2:1989 <i>Method of test on a single small vertical insulated wire or cable</i>
	BS 6469 <i>Insulating and sheathing materials of electric cables</i>
IEC 811-1-3:1985	Section 1.3:1992 <i>Methods for determining the density — Water absorption tests — Shrinkage test</i>

## National annex NB (informative)

### Guidance on test sample mounting

The following guidance applies to sections 3, 4 and 5 and to the standard ladders and wide ladders shown in Figure 2, Figure 2a, Figure 3, Figure 3a, Figure 3b and Figure 3c.

#### a) Cables with a conductor cross section not exceeding 35 mm<sup>2</sup>

When mounting the test pieces, the first test piece should be positioned approximately in the centre of the ladder and further test pieces added on either side so that the whole array of test pieces is approximately centred on the ladder.

If a second layer of test pieces is required after the full width of the ladder has been utilized for the first layer, then the first test piece of the second layer should be positioned approximately in the centre of the ladder and further test pieces added on either side so that the whole array of test pieces of the second layer is approximately centred on the ladder.

#### b) Cables with a conductor cross section exceeding 35 mm<sup>2</sup>

1) *Designation F/R*. When mounting the test pieces, the first test piece should be positioned approximately in the centre of the ladder and further test pieces added on either side so that the whole array of test pieces is approximately centred on the ladder.

If a second layer of test pieces is required after the full width of the ladder has been utilized for the first layer, then the first test piece for the second layer should be positioned on the rear of the ladder approximately in the centre of the ladder, but positioned in the gap between test pieces on the front of the ladder as shown in Figure 3c. Further test pieces should be added on either side so that the whole array of test pieces of the rear layer is approximately centred on the ladder.

2) *Designation F*. When mounting the test pieces, only a single layer should be used and the first test piece should be positioned approximately in the centre of the ladder and further test pieces added on either side so that the whole array of test pieces is approximately centred on the ladder.

---

# BSI — British Standards Institution

BSI is the independent national body responsible for preparing British Standards. It presents the UK view on standards in Europe and at the international level. It is incorporated by Royal Charter.

## Revisions

British Standards are updated by amendment or revision. Users of British Standards should make sure that they possess the latest amendments or editions.

It is the constant aim of BSI to improve the quality of our products and services. We would be grateful if anyone finding an inaccuracy or ambiguity while using this British Standard would inform the Secretary of the technical committee responsible, the identity of which can be found on the inside front cover. Tel: 020 8996 9000. Fax: 020 8996 7400.

BSI offers members an individual updating service called PLUS which ensures that subscribers automatically receive the latest editions of standards.

## Buying standards

Orders for all BSI, international and foreign standards publications should be addressed to Customer Services. Tel: 020 8996 9001. Fax: 020 8996 7001.

In response to orders for international standards, it is BSI policy to supply the BSI implementation of those that have been published as British Standards, unless otherwise requested.

## Information on standards

BSI provides a wide range of information on national, European and international standards through its Library and its Technical Help to Exporters Service. Various BSI electronic information services are also available which give details on all its products and services. Contact the Information Centre. Tel: 020 8996 7111. Fax: 020 8996 7048.

Subscribing members of BSI are kept up to date with standards developments and receive substantial discounts on the purchase price of standards. For details of these and other benefits contact Membership Administration. Tel: 020 8996 7002. Fax: 020 8996 7001.

## Copyright

Copyright subsists in all BSI publications. BSI also holds the copyright, in the UK, of the publications of the international standardization bodies. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI.

This does not preclude the free use, in the course of implementing the standard, of necessary details such as symbols, and size, type or grade designations. If these details are to be used for any other purpose than implementation then the prior written permission of BSI must be obtained.

If permission is granted, the terms may include royalty payments or a licensing agreement. Details and advice can be obtained from the Copyright Manager. Tel: 020 8996 7070.